

Weekly DI TESTING

COND= Conductivity
RES = Resistivity
TDS = Total Dissolved Solids
ORP_PPM = Free Chlorine

Record #	Measurement	Value	Unit	Date	Time
1	COND	0.06	uS	4/25/11	13:20:08
2	RES	17.9	MOhm	4/25/11	13:20:52
3	TDS	0	ppm	4/25/11	13:21:08
4	ORP_PPM	0.1	ppm	4/25/11	13:22:25
5	pH	5.53		4/25/11	13:23:42
6	COND	0.06	uS	4/26/11	7:28:09
7	RES	18.3	MOhm	4/26/11	7:28:56
8	TDS	5.81	ppm	4/26/11	7:29:14
9	ORP_PPM	0.1	ppm	4/26/11	7:29:42
10	pH	6.78		4/26/11	7:30:15
11	COND	0.08	uS	4/27/11	9:10:47
12	RES	18.3	MOhm	4/27/11	9:11:11
13	TDS	0	ppm	4/27/11	9:11:18
14	ORP_PPM	0.1	ppm	4/27/11	9:11:24
15	pH	7.72		4/27/11	9:12:28
16	COND	0.05	uS	4/28/11	10:15:45
17	RES	17.8	MOhm	4/28/11	10:17:46
18	TDS	0	ppm	4/28/11	10:17:55
19	ORP_PPM	0.1	ppm	4/28/11	10:18:16
20	pH	7.88		4/28/11	10:18:31
21	COND	0	uS	4/29/11	10:25:20
22	RES	17.4	MOhm	4/29/11	10:26:04
23	TDS	0	ppm	4/29/11	10:26:13
24	ORP_PPM	0.1	ppm	4/29/11	10:26:22
25	pH	6.04		4/29/11	10:26:33
26	COND	0	uS	5/2/11	11:30:19
27	RES	18.8	MOhm	5/2/11	11:30:43
28	TDS	0	ppm	5/2/11	11:30:53
29	ORP_PPM	0.1	ppm	5/2/11	11:31:05
30	pH	5.53		5/2/11	11:31:08
31	COND	0.06	uS	5/3/11	11:35:34
32	RES	18.3	MOhm	5/3/11	11:36:29
33	TDS	0	ppm	5/3/11	11:36:35
34	ORP_PPM	----	ppm	5/3/11	11:36:43
35	pH	7.84		5/3/11	11:36:47
36	COND	0.08	uS	5/4/11	11:27:59
37	RES	18.5	MOhm	5/4/11	11:28:22
38	TDS	0	ppm	5/4/11	11:28:31
39	ORP_PPM	0.1	ppm	5/4/11	11:28:51
40	pH	6.29		5/4/11	11:28:53
41	COND	0.11	uS	5/9/11	15:22:29

42	RES	18.2	MOhm	5/9/11	15:22:44
43	TDS	0	ppm	5/9/11	15:22:53
44	ORP_PPM	0.1	ppm	5/9/11	15:24:56
45	pH	6.32		5/9/11	15:25:00
46	COND	0.08	uS	5/11/11	15:50:14
47	RES	18.5	MOhm	5/11/11	15:50:37
48	TDS	0	ppm	5/11/11	15:50:50
49	ORP_PPM	0.1	ppm	5/11/11	15:51:05
50	pH	6.53		5/11/11	15:51:10
51	COND	0.05	uS	5/16/11	10:21:05
52	RES	17.9	MOhm	5/16/11	10:21:16
53	TDS	0	ppm	5/16/11	10:21:22
54	ORP_PPM	0.1	ppm	5/16/11	10:21:41
55	pH	5.99		5/16/11	10:21:52